




उपायुक्त कार्यालय, रेवाड़ी।
DEPUTY COMMISSIONER OFFICE, REWARI

Fire No Objection Certificate

Principal, Delhi Public School village-Jonawas Tehsil & Distt. Rewari has applied for renewal Fire No Objection Certificate for school building. Fire No Objection Certificate has been renewed to above school by this office vide letter No. 2039-40/PLA dated 04.12.2018 which is valid up to 11.12.2019.

Upon the report of Fire Station Officer, Rewari vide his letter No. FSR-598 dated 25.10.2019 (Copy enclosed) there is no objection for renewal of Fire No Objection Certificate subject to condition that school will keep complying with the observations made by Fire Station Officer, Rewari. In addition all other terms and conditions as applicable and imposed by the Govt. from time to time will also have to be complied with. This No Objection Certificate is renewed up to 11.12.2020 with effect from issuing date.

Encl.:- Copy of report of Fire Station Officer, Rewari No. FSR-598 dated 25.10.2019.


(Vikas Yadav, HCS)
City Magistrate, Rewari
For Deputy Commissioner,
Rewari.

Endst. No. 176-77 /PLA


Dated 31/10/19.

A copy is forwarded to the following for information and necessary action:-

1. Principal, Delhi Public School village-Jonawas Tehsil & Distt. Rewari.
2. Fire Station Officer, Rewari w.r.t. his letter No. FSR-598 dated 25.10.2019.


Principal
Delhi Public School
Rewari




(Vikas Yadav, HCS)
City Magistrate, Rewari
For Deputy Commissioner,
Rewari.

अधिकारी,

महोदय,

PSR/2019/598

दिनांक 25/10/20

Renewal of Fire NOC of M/s Delhi Public School.

उपरोक्त विषय पर Online Application No. 150891923000258
के संदर्भ में।

विषयाधीन मामले में अनुरोध है कि M/s Delhi Public School, Village- Jonawas, Tehsil & Distt. - Rewari की फायर फाईटिंग सिस्टम की NOC आगामी वर्ष के लिए नवीनीकरण की जानी है। अग्निसुरक्षा की दृष्टि से इस स्थल का मौका देखा गया। निम्न विवरण इस प्रकार से है।

M/s Delhi Public School, Village- Jonawas, Tehsil & Distt. - Rewari में

1. इस स्थल की ऊँचाई 15 मीटर से कम है।
2. इस स्थल तक दमकल वाहन आसानी से जा सकता है।
3. इस स्थल के ऊपर बिजली की तार/लाइन नहीं है।
4. इस स्थल पर अग्निशमन यंत्र पर्याप्त मात्रा में लगे हैं। जो इस समय चालू हालत में हैं।
5. इस स्थल पर UG टैंक बना हुआ है जिस पर दो पम्प लगे हुए हैं व होजरील ओर हाईडेंट भी लगा है।
6. इस स्थल पर G+2 Floor की बिल्डिंग बनी हुई है व पानी की व्यवस्था हेतु बोरेवेल का प्रावधान किया हुआ है।
7. फायर EXIT पर्याप्त मात्रा में लगे हुए हैं।
8. नहलपूर्ण दूरभाष नं० मेन गेट पर सिक्योरिटी रूप में लिखे हैं।

अतः आपसे अनुरोध है कि M/s Delhi Public School, Village- Jonawas, Tehsil & Distt. - Rewari ने NBC 2016 Part-IV के अनुसार सभी अग्निसुरक्षा प्रबन्ध किए हुए हैं जो इस समय वर्किंग आर्डर में हैं। अतः इसकी NOC का आगामी एक वर्ष के लिए नवीनीकरण करने में इस कार्यालय को कोई आपत्ति नहीं है। मांगी गई रिपोर्ट आपकी सेवा में आवश्यक कार्यवाही हेतु प्रेषित है।


Principal
Delhi Public School
Rewari


दमकल केंद्र अधिकारी
रेवाड़ी।